

Installation Guide

EG2-S Ethernet Gateway



iLight


Usk House, Lakeside
Llantarnam Park,
Cwmbran,
NP44 3HD, UK

t: +44 (0)1923 495495
e: enquiries@iLight.co.uk
www.iLight.co.uk


EU Authorised Representative
Cooper Lighting Netherlands B.V.
High Tech Campus
HTC 48
Eindhoven
5656 AE

E&OE. iLight reserve the right to make changes to the equipment without prior notice.
© Signify Holding


Doc No: 9850-000916-00



Typical Schematic



Mounting & Installation




EG2-S must be mounted in a suitable enclosure to provide regulatory protection from electric shock hazard as well as protecting the iCANnet data network from tampering that could lead to reduced network security.

Ensure selected enclosure provides adequate cooling ventilation.


Fixing to DIN rail

1. Fix top clips over DIN rail.
2. Pull down bottom clip using screwdriver.
3. Close module towards DIN rail.
4. Push up bottom clip to fix securely to DIN rail.



Removing from DIN rail

1. Pull down bottom clip with screwdriver.
2. Lift module away from DIN rail.



Technical Data

Electrical & Mechanical

Control: Via iLight network connection
Supply: +10 - 24V DC @ 750 mA Max (via external power supply)
Terminal Size: iCANnet cable size: 5 x 1mm². Power cable size: 2 x 1mm²
Protection: Provided by installer
Recommended Cable: iCANnet Network Cable
Ambient temperature: 2°C – 50°C
Relative humidity: 5% - 95% max, non-condensing
IP rating: IP20
Installation: Installation must be carried out by a suitably qualified electrician and installed in a suitable DINrail enclosure.
Dimensions: 106mm (w) x 91mm (h) x 62mm (d)
Weight: 0.22kg

Software

For programming EG2-S, Device Editor software is required.
Please consult your iLight representative for latest versions.

EG2-S

Ethernet Gateway

Device LEDs and Buttons

Status LED

Green LED flashes – device OK

Data LED

Red LED flashes when messages sent on network.


Device Identification

Press and release switch.

Sending a message to identify the device on the network (red Data LED flashes)

iCAN network wiring

Cable connections to the iCAN network are made to a removable 5-way connector block located on the EG2-S



Function	iCANnet Cable Colour
0V	Black
CAN L	Blue
Shield	Silver
CAN H	White
+V	Red

Maximum segment distance: 500m (1640 ft)
 Devices per segment: 100 (without bridge or repeater)
 Consult iLight for information on alternative cable types.

IMPORTANT NOTE: Connecting a mains potential cable to the iCAN Network terminals is likely to damage the unit and other devices connected, and invalidate warranty.

Typical Connection Diagram

Power Supply Jumper


Enables iLight Network BUS power when in the 'ON' position. Disables iLight Network BUS power when removed or in the 'OFF' position.
Caution: This product requires 10-24V@750mA. When using the network to power this device ensure adequate power is available on the network.

Power Supply
 +10 - 24V DC @ 750 mA Max

Device Identification Switch

Data LED

Status LED



Connection to non-PoE port on ethernet switch

Connection to the iLight Network

iLight Network Termination

Network termination

EG2-S is supplied with termination disabled as standard. If it is connected as an end device on the iCAN network, the jumper will need to be moved to enable termination.

To enable termination, move the jumper downwards from the top two pins to the bottom two pins.

